

Aqua-Tech Laboratory

JOSEPH F. CALABRO, Ph.D.—LABORATORY DIRECTOR



Technical Expertise in Water Quality Monitoring, Laboratory Analyses, and Treatment Processes
1 Wilderness Drive, Mountaintop, PA 18707 Tel. (570) 868-0915. Fax (570) 868-0299. e-mail-aquatech@epix.net

July 5, 2011

Juanita Krieger
820 W. Avenue
Bear Creek Twp., PA 18702

RE: Analyses of Mountain/Meadow Run Lakes for Escherichia coli

Samples were collected on June 27, 2011 by Juanita Krieger

Sample Site No	<u>Escherichia coli</u> per 100 ml
1	5
2	32
3	64
4	7
5	62
6	18
7	8
8	23
9	6
10	3
11	7
12	9
13	2
14	5
15	20
16	15

The above water was collected by representatives utilizing sampling procedures as prescribed under the Pa Safe Drinking Water Act. Samples were analyzed for the detection of *Escherichia coli* in lake water. The data obtained from the above sampling event, indicates that the Lake water is safe for bathing. The PA State Health Standard is 235 *E. coli* per 100 ml.

Respectfully submitted,

Joseph F. Calabro, PhD
Laboratory Director